

ENTERED

COMPLAINT, INCIDENT, AND NOTIFICATION REPORT FORM

Type (Circle One): C I N

CASE NUMBER: 18-05-25 - 01

Received Date: 05/25/18 Received Time: 1:58 AM Received By: AM Lead: DV

Incident Date: 5/25/18 Incident Time: Assigned to: Assigned Date:

COMPLAINANT / REPORTING PARTY:
 Name: CCC - FPD Dispatch RP is from Facility Anonymus
 Organization: _____
 Primary Phone Number: _____ Secondary Phone Number: _____
 Email: _____
 Address: _____
 City: _____ State: _____ Zip Code: _____

FACILITY / LOCATION OF INCIDENT:
 Name: _____ CUPA Facility I.D.: _____
 Phone Number: _____
 Address: EB 80 @ POMONA EXIT Unit: _____
 City: CROCKETT State: CA Zip Code: _____
 Location Description: EB 80 @ POMONA EXIT

INITIAL INCIDENT DESCRIPTION:
 OVERTURN BIG RIG RESULTING IN DIESEL SPILL

INCIDENT TYPE / DESCRIPTION: 0 1 2 3
 Community Warning System Level (Circle Highest Level): N/A 0 1 2 3

FACILITY	ISO / MCAR	TRANSPORTATION	MISCELLANEOUS
<input type="checkbox"/> Fire or Explosion	<input type="checkbox"/> Fatality (one or more)	<input type="checkbox"/> Tank Truck	<input type="checkbox"/> Storm Drain/Creek
<input type="checkbox"/> Spill or Release	<input type="checkbox"/> > 24 hrs. Hospital, 3 or more people	<input type="checkbox"/> Railroad	<input type="checkbox"/> Drug Lab
<input type="checkbox"/> Startup or Shutdown	<input type="checkbox"/> Flammable Vapor Cloud > 5,000 lbs.	<input type="checkbox"/> On Water	<input type="checkbox"/> Disposal/Abandonment
<input type="checkbox"/> Flaring		<input type="checkbox"/> Pipeline	<input type="checkbox"/> Odor Complaint
<input type="checkbox"/> Upset		<input type="checkbox"/> Fuel Tank	<input type="checkbox"/> Other:

Time Enroute to Scene: 20min Time Arrived On Scene: 0245 Time Departed From Scene: 0545

REFERRED TO OTHER AGENCY:



DTSC STATE FUNDING (if applicable): CLU/ERER Number:	STORMWATER STATUS (if applicable): <input type="checkbox"/> Actual Discharge <input type="checkbox"/> Potential Discharge
--	---

AGENCIES ON SCENE OR NOTIFIED:

Agency Type	Agency	O/N	Contact Person	Phone Number	Case Number
Fire Department	Rodeo-Hercules FPD	O	Derek Johnson	925-457-0358	
Law Enforcement	CHP	O	Sergeant Koven #17494	925-646-4990	123-5/28/18
Air District					
State OES					
	F&W	O	Ryan Thiem #732, Warden	415-209-4739	
Fire Department	RFD - Hazmat	O	Victor Bontempo		
	CalTrans	O	Ismael Vega, Area superintendent	510-772-8030 (c)	
Clean Up Contractors	Patriot Env	O			

REPORT:

5/25/2018
 At approx 0145 CCHSHMP received and responded to notification from CCCFPD Dispatch of an overturned tractor and trailer with unknown cargo on I-80 East bound at Pomona St. Exit near the Carquinez Bridge, in Crockett.

CCHSHMP dispatched HM1 & HM3 and one HMS directly to the scene.

Approx 0225: HM1 departs for scene
 Approx 0245: HM3 arrives on scene

Upon arrival CCHSHMP met to discuss the incident with the incident commander (CHP) and RFD-Hazmat & Rodeo-Hercules FPD.

Initial Assessment:
 The tractor collided with a wall ruptured its fuel tanks and caught fire, the fire department extinguished the fire with foam and approx 1500 gallons of water. Most of the fuel and engine fluids burned in the fire and some released to Highway and storm drain. The trailer was later identified to be hauling pineapples.

Weather Conditions: night, cold, light rain on and off, light wind

Hazmat Operation:
 CCHSHMP objectives were to perform air monitoring and provide assistance to the Incident Commander until a clean up contractor arrived and began clean up operations.

CCHSHMP donned level D PPE and performed air monitoring of the roadway and storm drain. PID/CGI reading at roadway are non-detect and within normal range. At storm drain CGI readings are within normal range, PID reading at ground level are 15ppm. CCHSHMP advised the Incident Commander that OSHA does not have a PEL for diesel fuel, but it is designated as an OSHA Select Carcinogen.

CCHSHMP along with F&W attempted to find the storm drain outlet with the diesel release. CCHSHMP performed air monitoring at several storm drains on I-80, Pomona St Exit and Vista Del Norte St. Readings were non-detect and within normal range.

Mitigation:
 CalTrans dispatched a street sweeper to clean up road debris and contacted Patriot Environmental to perform clean up operations. CCHSHMP met to discuss the incident with CalTrans area superintendent, CCHSHMP discussed training requirement for hazwaste workers, management of any hazwaste generated and capturing any fuel or vehicle fluids if storm drains are flushed.
 *CCHSHMP will consider having clean up contractors escorted to scene when roads are delayed/closed.

Departs: HM1 departs scene Approx 0545

Additional Required Items: Bill of Lading, Request for Invoice, and Site Safety Plan

Report Prepared by: DV



Hazardous Materials Spill Report: Cal OES Control #:18-3372

Warning Center to: daniel.vazquez

05/25/2018 03:13 AM

Governor's Office of Emergency Services
Hazardous Materials Spill Report

DATE: 05/25/2018 | RECEIVED BY Cal OES: Blake Tyson | Cal OES CNTRL
#:18-3372
TIME: 0304 | RECEIVED BY OSPR: | NRC#:

1.a. PERSON NOTIFYING Cal OES

1. NAME: Hawa Bassa | 2. AGENCY: Caltrans Oakland
3. PHONE #: 510-286-6359 | 4. EXT: | 5. PAGER #:

1.b. PERSON REPORTING SPILL (If different from above):

1. NAME: | 2. AGENCY:
3. PHONE #: | 4. EXT: | 5. PAGER #:

2. SUBSTANCE TYPE:

a. SUBSTANCE: / b.QTY: / Amount / Measure / c. TYPE / d. OTHER / e.
PIPELINE / f. Vessel Over => 300 tons

1. Fuel - Diesel Type, mixed w water / = / 280 / Gal(s) / PETROLEUM / /
No / No

2.

3.

g. DESCRIPTION: Tanker truck accident and fire extinguishment efforts
caused the release, material flowed onto asphalt then into a storm drain
leading to an unknown waterway, FD is handling the containment, unknown who
is performing clean up.

h. CONTAINED: Yes | i. WATER INVOLVED: Yes

j. WATERWAY: Storm drain | k. DRINKING WATER IMPACTED: No

l. KNOWN IMPACT: Road Closure

3.a. INCIDENT LOCATION: EB Hwy 80 JWO Pomona Rd

b. CITY: Crockett | c. COUNTY: Contra Costa County | d. ZIP:

4. INCIDENT DESCRIPTION:

a. DATE: 5/25/2018 | b. TIME(Military): 0131 | c. SITE: Road |

d. CAUSE: Collision

e. INJURIES: No | f. FATALITY: No | g. EVACUATIONS: No | h.

CLEANUP BY: Unknown

e. INJURIES #: | f. FATALS #: | g. EVACS #:

5. SUSPECTED RESPONSIBLE PARTY:

a. NAME: | b. AGENCY: BS Trucking

c. PHONE#: | d. EXT:

e. MAIL ADDRESS:

f. CITY: | g. STATE: CA | h. ZIP:

6. NOTIFICATION INFORMATION:

a. ON SCENE: Cal Trans, CHP, Fire Dept. | b. OTHER ON SCENE:
c. OTHER NOTIFIED:
d. ADMIN. AGENCY: Contra Costa County Health Services Department
e. SEC. AGENCY:
f. ADDITIONAL COUNTY: Alameda County , Marin County g.
ADMIN. AGENCY: Alameda County Environmental Health , Marin County Waste
Management Office
h. NOTIFICATION LIST: DOG Unit: | RWQCB Unit: 2

AA/CUPA, DTSC, RWQCB, US EPA, USFWS, DFG-OSPR, AIR RESOURCES BD, LANDS,
PARKS & REC, USCG, Co/WP, Co/Hlth, Co/E-Hlth

CONFIDENTIAL REMARKS:

Created by Warning Center on 5/25/2018 3:04:40 AM Last
Modified by Warning Center on 5/25/2018 3:13:19 AM

California State Warning Center
Governor's Office Emergency Services
Phone: (916) 845-8911
Warning.Center@oes.ca.gov

Link to Spill Report:

https://urldefense.proofpoint.com/v2/url?u=http-3A_w3.calema.ca.gov_operation_al_malhaz.nsf_SpillAllDocs_6808F6CCB3BAE4B18825829800375C1E-3FOpenDocument&d=DwIBAg&c=RpR9LiQNIoGO8A8CMgA1NQ&r=MB1G3zdKJWEKBPzCYVcMr2RZjh30gsEA40fuyUr4vvo&m=-mXZ5fzNXlnLzuwbh7eroYNNcgjrWHAKkYO6z7HNxug&s=hhMEWYzFLLIlqTogj6uWpUIIcW6XJT_CP1-qa9fWKzI&e=